



EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO

EULEX KOSOVO

Ndertesë Farmëd
“Muharrem Fejza” p.n.
Lagja e Spitalit
10000 Pristina, Kosovo
www.eulex-kosovo.eu

CORRIGENDUM (2)

PUBLICATION REFERENCE: PROC/374/12/Supply Installation and Maintenance of Water Fire Hydrants (EuropeAid/133718/L/SUP/XK)

The following corrections are made to the Annex II – Technical Specifications

A) Item 1: Supply and installation of Indoor Fire Water Hydrants

The former text:

- Wall-mounted hydrant cabinet dim. min. 500x500x140mm according to DIN 14461-1. Galvanized 1mm thick tin with air ventilation holes on front door. Four installations holes on the back. In red colour RAL 3001. With pictogram according EN 671 und VBG 125 dimension 200X250mm.

Shall now read:

- Wall-mounted hydrant cabinet dim. min. 500x500x140mm according to DIN 14461-1. Galvanized 1mm thick tin. In red colour RAL 3001. With pictogram according EN 671 und VBG 125 dimension 200X250mm.

B) The following point 5 has been added under description of Annex II – Technical Specifications

5. After contract signature, when the Project Manager issues a purchase order, the awarded Contractor will be requested to design a fire hydrant network, for each order, and submit it for approval prior to the commencement of works.

C) The following Article 14 has been added under Special Conditions of Draft Contract.

Article 14 Contractor’s drawings

Upon issuance of a purchase order the Contractor will also be required to submit a design for a fire hydrant network, prior to the commencement of any works, as stipulated in point 5 of Annex II of Technical Specifications.

All other terms and conditions of the Tender Dossier remain unchanged. The above alterations and corrections to the Tender Dossier are integral part of the Tender Dossier.

Please regularly check EULEX Website where additional clarifications may be published until **28th December 2012** at <http://www.eulex-kosovo.eu/en/tenders/112-water.php>