



EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO

EULEX KOSOVO

Ndertesë Farmëd

“Muharrem Fejza” p.n.

Lagja e Spitalit

10 000 Pristina, Kosovo

Tel: + (381) 38 78 2000

<http://www.eulex-kosovo.eu>

CLARIFICATIONS (1)

PUBLICATION REFERENCE: PROC/447/13/Construction Materials No. 3 (EuropeAid/135091/M/SUP/XK)

1. Questions regarding Part A: Instructions to Tenderers

No	Lot /Item	Question	Answer
1	N/A	Can we apply in the tender only in some lots or we should apply in total 6 lots.	Please refer to Point 10 of the Contract Notice: “ <i>Tenderers may submit only one tender per lot...</i> ” and Article 7 of Part A: Instructions to Tenderers: “ <i>The tenderer may submit a tender for one lot, several or all of the lots...</i> ”

2. Questions regarding Annex II+III Technical Specifications:

No	Lot /Item	Question	Answer
1	LOT 3: Doors, Windows and Locks	Please If I can have plans or images of windows and doors as required in the tender for lot 3, for the doors and windows.	At the moment we have no drawings. However, in line with Annex IV, Budget Breakdown, of the tender dossier Tenderers are requested to quote a square meter price for windows.
2	LOT 3: Doors, Windows and Locks	Also, I need some important details is the thermal transmittance of the window (Uw), frame (Uf) and glass (Ug).	Please refer to the below question and answer number three (3).
3	LOT 3: Doors, Windows and Locks	The applicant gives an indication $U = 1.4 \text{ W/m}^2\text{K}$., I am supposing that this is a total transmittance of the window (Uw) or what.	In the case of items one (1), two (2) and nine (9) the amount refers to the total transmittance of the window. Whereas, in the case of items three (3), eight (8) and ten (10) the amount refers to the glass.

EoT.